

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

## Product

Automatic transfer switching equipment (ATSE)

## Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.  
No. 1, Chint Road, Chint industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang  
China

## Name and address of the manufacturer

Zhejiang Chint Electrics Co., Ltd.  
No. 1, Chint Road, Chint industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang  
China

## Name and address of the factory

Note: When more than one factory, please report on page 2

☐ Additional information on page 2Zhejiang Chint Electrics Co., Ltd.  
No. 1318, Binhai No. 2 Avenue, Economic and Technical Development Zone, 325025 Wenzhou,  
Zhejiang  
China

## Ratings and principal characteristics

3P and 3P+N  
Ue: 400 / 415 Vac, Ie: 10, 16, 25, 32, 40, 50, 63 A (NXZM-63S, NXZM-63H),  
63, 80, 100, 125 A (NXZM-125S, NXZM-125H), 50 / 60 Hz  
Class CB, AC-33B, Ui: 800 V, Uimp: 8 kV  
Icm: 52,5 kA (NXZM-63S, NXZM-125S), 105 kA (NXZM-63H, NXZM-125H)  
Icn: 25 kA (NXZM-63S, NXZM-125S), 50 kA (NXZM-63H, NXZM-125H)  
See annex for further ratings

## Trademark (if any)

CHINT

## Customer's Testing Facility (CTF) Stage used

## Model / Type Ref.

NXZM-63S, NXZM-63H, NXZM-125S and NXZM-125H

## Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

## A sample of the product was tested and found to be in conformity with

IEC 60947-6-1:2005, IEC 60947-6-1:2005/AMD1:2013

## As shown in the Test Report Ref. No. which forms part of this Certificate

3312030.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands